

ANALYTICAL REPORT

Report Code: Rev 1.0 (2023)

Report ID	Report Date	Page
R-104103208-26	02/07/2026	1 of 2

Customer Name \ Address				
SANABIL \ شركة مدارس سنابل للنور للتعليم الاجنبي الاهلية \ Sanabil Alnoor schools company				
Sample #	Description	Sample Category	Collected By	Received Date\Time
2256331	Drinking water		By Customer	01-Jul-2026

Test	Test Method	LOQ	Unit	Spec MEWA-2024	Sample # / Test Result				
					2256331	32322	32321	32320	32319
Nitrite	APHA-4500-NO2-B	N/A	mg/L	Max 3	0.02				
Nitrate*	APHA-4500-NO3-E	2	mg/L	Max 50	7.6				
Chloride*	APHA-4500-Cl-B	N/A	mg/L	Max 250	9.2				
Sulfate*	APHA-4500-SO4-E	N/A	mg/L	Max 250	23				
pH	APHA-4500-H+-B	N/A	-	6.5 to 8.5	7.1				
Iron	APHA-3500-Fe-B	N/A	mg/L	Max 0.3	0.09				
Total Dissolved Solids	By Calculation	N/A	mg/L	100 to 1000	140.4				
Coliform	APHA-9222-B	N/A	MPN/100 ml	Max 0	0				
Fecal Coliforms	APHA-9222-D	N/A	MPN/100 ml	Max 0	0				
Total Hardness	APHA-2340-B	N/A	mg/L	Max 320	90				
Ammonia	APHA 4500 NH3 F	N/A	mg/L	Max 0.5	0.03				
Turbidity	APHA-2130-B	N/A	NTU	Max 5	0.11				
Colour	APHA-2120-C	5	pt/Co	Max 15	0				
Odour	APHA-2150-B	N/A	Dilution number	Not Found	Not Found				
Taste	APHA-2150-B	N/A	Dilution number	Not Found	Not Found				

- Test Performed Under lab temp range (20 - 30 °C).

- Results refer only to checked samples.

* Test name with Asteric (*) postfix are ISO accredited.

- Test name in Bold are Out Off-Specifications.

Where statements of conformity are made in this report, the following decision rules are applied:

Pass: results ± expanded uncertainty within limits/specification.**Pass:** results within limits/specification but overlap when expanded uncertainty is taken into account.**Fail:** results ± expanded uncertainty exceeds limits/specification.**Fail:** results exceed limits/specification but overlap when expanded uncertainty is taken into account.

ANALYTICAL REPORT

Report Code: Rev 1.0 (2023)

Report ID	Report Date	Page
R-104103208-26	02/07/2026	2 of 2

Approval

Approved By: Mohamed Mahdy Alyami

Function: Laboratory Section Head

Date: 02-Jul-2026

Signature:



Contact us

NWC Cluster: SOUTHERN

Lab: Najran DW

Email: Moalsaed.c@nwc.com.sa

Tel: +966 568982662